



EU Declaration of Conformity



C-TEC Range Analogue Addressable Evacuation Panels

Product Model Designation(s)

- EAP1/8/CA/CHASSIS 1 Loop 8 Zone Evacuation Panel, Chassis Only, CAST Protocol
- EAP2/8/CA/CHASSIS 2 Loop 8 Zone Evacuation Panel, Chassis Only, CAST Protocol
- EAP4/16/CA/CHASSIS 4 Loop 16 Zone Evacuation Panel, Chassis Only, CAST Protocol
- EAP4/24/CA/CHASSIS 4 Loop 24 Zone Evacuation Panel, Chassis Only, CAST Protocol
- EAP4/32/CA/CHASSIS 4 Loop 32 Zone Evacuation Panel, Chassis Only, CAST Protocol
- EAP4/40/CA/CHASSIS 4 Loop 40 Zone Evacuation Panel, Chassis Only, CAST Protocol
- EAP4/48/CA/CHASSIS 4 Loop 48 Zone Evacuation Panel, Chassis Only, CAST Protocol

Manufactured by C-TEC at:

Computationics Ltd (Trading as C-TEC), Challenge Way, Martland Park, Wigan, WN5 0LD, United Kingdom

are in conformity with the provisions of the following EU Directive(s):

- 2014/30/EU: Electromagnetic Compatibility Directive (EMC)
- 2014/35/EU: Low Voltage Directive (LVD)
- 2011/65/EU: Restriction of Use of certain Hazardous Substances Directive (RoHS)

The products to which this declaration relates have been tested to and are in conformity with the following standards:

- EN 50130-4: 2011+A1:2014
Alarm Systems – Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder and social alarm systems.
- EN 61000-6-3: 2007+A1: 2011
Electromagnetic compatibility (EMC) – Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments.
- EN 62368-1:2014+A11:2017
Audio/Video, Information & Communication Technology equipment — Safety — Part 1: Safety requirement
- BS EN IEC 63000:2018
Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances.

In addition, the products satisfy the essential requirements of the following standards when correctly installed:

- BS 8629:2019
Code of practice for the design, installation, commissioning and maintenance of evacuation alert systems for use by fire and rescue services in buildings containing flats

Empowered Signatory of Company

I, the undersigned, hereby declare on behalf of Computationics Limited that the products listed above comply with the requirements of the standards listed above which gives presumption of conformity with the essential requirements of the directives listed above.

Name: Daniel Foster

Position: Head of Science

Signature:

Date: 01/12/2020

Place: Wigan, UK